

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

BISOL Production, Ltd.
Latkova vas 59a
SI - 3312 PREBOLD

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules



Valid from: 2025-07-16

Valid until: 2030-07-15

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC TS 63342:2022
Remark:	Test duration: 168*2 hours The module types are deemed "LETID non-sensitive"
Registered No.:	44 780 25 406749 - 187
Manufacturer and factory(-ies):	see Annex 1
Test Report No.:	492013898.001
File No.:	PVP03011/24P-05

A handwritten signature in purple ink, appearing to read "R. K. 1".

TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2025-07-16

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 25 406749 - 187

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: PVP03011/24P-05

2025-07-16

Manufacturer and factory(-ies):

Manufacturer: **BISOL Production, Ltd.**
Latkova vas 59a
SI - 3312 PREBOLD

Factory: **BISOL Production, Ltd.**
Latkova vas 59a
SI - 3312 PREBOLD

Factory inspection report no.: 862011058.001_R2

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	Single Glass PV Modules with 182mm x 91mm TOPCon Mono-crystalline Silicon Solar Cells 132 cells: BBO-xxx (xxx=525-535, in steps of 5) 108 cells: BDO-xxx (xxx=430-435, in steps of 5) 108 cells: BSO-xxx (xxx=430-435, in steps of 5) Remark: xxx indicates rated output power generated from front side under STC
Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II
Module types:	Single Glass PV Modules with 182.3mm x 105mm TOPCon Mono-crystalline Silicon Solar Cells 108 cells: BBO-xxx (xxx=490-520, in steps of 5) 96 cells: BDO-xxx (xxx=435-460, in steps of 5) 96 cells: BSO-xxx (xxx=435-460, in steps of 5) Remark: xxx indicates rated output power generated from front side under STC
Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II

Remark:

For detailed product information, please refer to CDF (Constructional Data Form).



TÜV NORD CERT GmbH
Certification Body
Consumer Products